Brihanmumbai Municipal Corporation
Mumbai Fire Brigade
Office of the Chief Fire Officer,
Byculla Command Centre Building,
1st Floor, Bapurao Jagtap Marg,
Byculla, Mumbai - 400 008.
Phones : 022-2300 1393/94/95
Fax : 022-2300 1392
E-mail : cfo.mfb@mcgm.gov.in
No. : FB/P/OD/701
Date : 10/08/22

This is to certify that M/s Kaustubha Udyog has shown the demonstration of IOT based **Ogauge** system to be fixed in inbuilt fire fighting system in the building.

The IoT based system provides the information about-

- Real time water pressure in the system
- Location of the site where fire system is being monitored on Google maps
- Historical data of pump on-off operations to evaluate the overall Health of the system for compliances and an audit trail
- Instant alerts to the authorities in the event of fire

The inbuilt relays and the gauge enable Ogauge to be fitted in any existing fire fighting system without any changes.

This IoT based system will help monitoring the status of fire fighting system in the building in real time and will help the building owner / occupier to monitor the compliance at all time.

(H. D. Harab)
Chief Fire Officer